



DEER PARK FIRE MARSHAL'S OFFICE

FIRE WATCH



These guidelines are to be followed when a building, or facility, within the City of Deer Park, provided with a required fire protection system is out of service. In addition, any other time a fire watch has been required by the Fire Marshal. Fire Watches for the purposes of these guidelines and any other requirements of the Fire Marshal's Office shall conform to the 2012 International Fire Code, as adopted and amended by the City of Deer Park.

Definitions

Fire Watch. A temporary measure intended to ensure continuous and systematic surveillance of a building or portion thereof by one or more qualified individuals or standby personnel when required by the fire code official, for the purposes of identifying and controlling fire hazards, detecting early signs of unwanted fire, raising an alarm of fire and notifying the fire department.

Standby Personnel. Qualified fire service personnel, approved by the Fire Marshal. When utilized, the number required shall be as directed by the Fire Marshal.

General Fire Watch Requirements

- 1) Upon determination that a required fire protection system is rendered inoperable or its continued operation is questionable, the Deer Park Fire Marshal's Office shall be notified immediately. It shall be the responsibility of the Fire Marshal to determine the level of protection required and prescribes such actions necessary to secure public safety and timely restoration of the required fire protection system.
- 2) Where required by the Fire Marshal's Office, an approved fire watch shall be provided until the fire protection system has been returned to service.
- 3) Persons providing fire watch shall be provided with at least one approved means for notification of the fire department and their only duty shall be to perform constant patrols of the protected premises and keep watch for fires.
- 4) A fee of \$40.00 per hour for a minimum of two hours is charged for each required fire watch personnel, when it is determined by the Fire Marshal's Office that Standby Personnel are necessary.
- 5) A representative of the building, or facility, shall contact the Fire Marshal's Office a minimum of 72 hours prior to a planned impairment, or immediately when impairment is not planned, to coordinate personnel for the Fire Watch.

Fire Watch Log

- 6) When required, the Fire Watch Log form shall be completed at the time intervals required by the Fire Marshal's Office.
- 7) Upon completion of repairs to the fire protection system and termination of the Fire Watch, a copy of this log shall be faxed or delivered to the Fire Marshal's office.

Fire Watch Personnel Duties

- 8) The personnel assigned to Fire Watch Duties shall meet the following criteria:
 - a) Shall sign the Notification of Fire Watch Responsibilities Form.
 - b) Shall not be required or permitted to perform any other duties.
 - c) Shall tour all the compromised area(s) of the building at intervals specified in the Fire Watch order.
 - d) Shall be physically capable of performing the duties of a Fire Watch
 - e) Have means of summoning the Fire Department if a fire is discovered – cellular telephone, portable radio, etc.



DEER PARK FIRE MARSHAL'S OFFICE

FIRE WATCH



- f) Shall be familiar with the layout and arrangement of the building being toured
- g) Shall have any and all keys necessary to properly and effectively check all affected areas of the building, and admit the emergency responders
- h) Shall be familiar with the Fire Alarm system and how to activate it
- i) Shall be familiar with the location and use of portable fire extinguishers
- j) Shall be familiar with the exits from the area he/she is touring
- k) Shall remain awake and alert for the entire period he is expected to provide such services
- l) Shall be familiar with the procedures to be followed if a fire is discovered, and the methods of notification of building occupants

Termination of Fire Watch

- 9) Fire Watch shall ONLY be terminated by the Fire Marshal, upon restoration of the Fire Protection System and certification that it is now 100% operational. The Fire Watch Log shall be completed, including the names of those performing such duties, and the name of the person who authorized the termination of same. A copy of the entire Fire Watch Log, Notification of Fire Watch Responsibilities Form from each person assigned to fire watch, and documentation reflecting that the required fire protection system has been restored must be forwarded to Deer Park Fire Marshal's Office. Faxed to 281-478-7289, Emailed to firemarshal@deerparktx.org or delivered in person to Fire Station #3, 2211 East X Street, Deer Park, TX 77536.



DEER PARK FIRE MARSHAL'S OFFICE
FIRE WATCH



**BUILDING REPRESENTATIVE
NOTIFICATION OF
FIRE WATCH RESPONSIBILITIES**

I _____, hereby acknowledge that the fire protection system protecting the property located at _____ Deer Park, TX has been rendered ineffective and a fire watch must be posted until such a time that the fire protection system is fully operational. I further acknowledge that I am responsible to ESTABLISH, INSTRUCT, AND MAINTAIN the required fire watch throughout the building or property. Failure to follow this order will make me subject to prosecution. If a fire or injuries result from a failure to comply with this order, I may be liable for damages to persons or property under provisions of the City Ordinance adopting the Fire Code.

I have received a copy of the Fire Watch Designee Notification of Fire Watch Responsibilities Form that must be signed by each person designated to conduct the fire watch. I have also received the Fire Watch Procedures and Fire Watch Log that must be maintained throughout the duration of the fire watch.

I understand that the fire watch may only be terminated upon approval from the Deer Park Fire Marshal's Office.

Building Representative (Print Name)

Date

Fire Marshal

Date



DEER PARK FIRE MARSHAL'S OFFICE
FIRE WATCH



**FIRE WATCH DESIGNEE
NOTIFICATION OF FIRE WATCH
RESPONSIBILITIES**

I _____, hereby acknowledge that the fire protection system protecting the property located at _____ Deer Park, TX has been rendered ineffective and a fire watch must be posted until such a time that the fire protection system is fully operational. I further acknowledge that I am responsible to conduct the required fire watch throughout the building or property. Failure to follow this order will make me subject to prosecution. If a fire or injuries result from a failure to comply with this order, I may be liable for damages to persons or property under provisions of the City Ordinance adopting the Fire Code.

I have received a copy of the Fire Watch Designee Notification of Fire Watch Responsibilities Form that must be signed by each person designated to conduct the fire watch. I have also received the Fire Watch Procedures and Fire Watch Log that must be maintained throughout the duration of the fire watch.

I understand that the fire watch may only be terminated upon approval from the Deer Park Fire Marshal's Office.

Fire Watch Designee (Print Name)

Date

Building Representative

Date



DEER PARK FIRE MARSHAL'S OFFICE

FIRE WATCH



FIRE WATCH LOG

(Please Print or Type)

PREMISES _____ DATE _____

ADDRESS _____

RESPONSIBLE PERSON PHONE _____

ORDERED BY _____ RECEIVED BY _____

CIRCUIT INTERVALS: 60-min 30-min 15-min

Table with 4 columns: TIME CHECK, OF, AREA(S) TOURED & CHECKED, CONDITIONS FOUND, FIRE WATCH INITIALS

BUILDING REPRESENTATIVE WHO TERMINATED: _____ PRINT NAME

FIRE MARSHAL REPRESENTATIVE WHO APPROVED TERMINATION: _____ PRINT NAME

TIME TERMINATED _____

NAME OF FIRE ALARM/SPRINKLER COMPANY COMPLETING REPAIRS: _____

Upon completion of Fire Watch, this log must be forwarded to: DEER PARK FIRE MARSHAL'S OFFICE Faxed to 281-478-7289, Emailed to firemarshal@deerparktx.org or delivered in person to Fire Station #3, 2211 East X Street, Deer Park, TX 77536.



DEER PARK FIRE MARSHAL'S OFFICE
FIRE WATCH



FIRE WATCH PROCEDURES

Scope

These procedures shall be followed when a Fire Watch is required by the Deer Park Fire Marshal's Office.

Purpose

Fire Watch is a temporary measure intended to ensure continuous and systematic surveillance of a building or portion thereof by one or more qualified individuals or standby personnel when required by the Fire Marshal, for the purposes of identifying and controlling fire hazards, detecting early signs of unwanted fire, raising an alarm of fire and notifying the fire department. This procedure is to provide uniform direction for the use, application, and documentation of a Fire Watch program where a required fire protection system for occupancy has been compromised or incapacitated.

Procedures

Notification

Upon determination that a required fire protection system is rendered inoperable or its continued operation is questionable, the Deer Park Fire Marshal's Office shall be notified immediately. It shall be the responsibility of the Fire Marshal to determine the level of protection required and prescribes such actions necessary to secure public safety and timely restoration of the required fire protection system.

Log

The affected premises, upon being directed to perform a Fire Watch, will fill out the Fire Watch Log and make entries on that form at the time intervals required by the Fire Marshal. Upon completion of repairs to the fire protection system and termination of the Fire Watch, a copy of this log shall be faxed or delivered to the Deer Park Fire Marshal's Office. Failure to maintain a log will result in a penalty assessment and possible evacuation of the building.

Duties

The personnel assigned to Fire Watch Duties shall meet the following criteria:

1. Shall sign the Notification of Fire Watch Responsibilities Form.
2. Shall not be required or permitted to perform any other duties.
3. Shall tour all the compromised area(s) of the building at intervals specified in the Fire Watch order.
4. Shall be physically capable of performing the duties of a Fire Watch
5. Have means of summoning the Fire Department if a fire is discovered – cell phone, portable radio, etc.
6. Shall be familiar with the layout and arrangement of the building being toured
7. Shall have all keys necessary to properly and effectively check all affected areas of the building, and admit the emergency responders
8. Shall be familiar with the Fire Alarm system and how to activate it
9. Shall be familiar with the location and use of portable fire extinguishers
10. Shall be familiar with the exits from the area he/she is touring
11. Shall remain awake and alert for the entire period he is expected to provide such services
12. Shall be familiar with the procedures to be followed if a fire is discovered, and the methods of notification of building occupants



DEER PARK FIRE MARSHAL'S OFFICE

FIRE WATCH



In Event of Fire

If a fire is discovered, the Fire Watch personnel shall be responsible to:

1. Notify the building occupants **immediately**
 - a. This may be accomplished by:
 - i. Activation of the fire alarm system (if those components are not compromised)
 - ii. Voice communication of need to leave building by use of Public Address System
 - iii. Voice hailing, door to door, or by runners
2. Notification of the Fire Department
 - a. This may be accomplished by:
 - i. Telephone call to 9-1-1 reporting the physical address, location, type and extent of fire, his/her name and telephone number and any other pertinent information
 - ii. Use of portable radio monitored by a constantly attended location that will make a telephone call for him/her
 - iii. Other approved means
3. Ensure that building is evacuated
 - a. Check all areas for occupants
 - b. Provide assistance to those evacuating
 - c. Direct persons as to where they must assemble
 - d. Attempt to locate the fire
 - e. Note location of occupants either unable or unwilling to evacuate and report same to Fire Department
4. Meet with the arriving Fire Department members
 - a. Advise the status of occupants
 - b. Advise location and extent of fire
 - c. Accompany them if requested
 - d. Provide access or keys to area if secured

Frequency of Tours

Tours of all compromised areas of the building shall be conducted at intervals not to exceed sixty (60) minutes from completion of the previous tour. Frequency of tours can be increased at the discretion of the Fire Marshal based on the hazards present and shall be reflected as such on the Fire Watch Log.

Termination of Fire Watch

Fire Watch shall ONLY be terminated by the Fire Marshal, upon restoration of the Fire Protection System and certification that it is now 100% operational. The Fire Watch Log shall be completed, including the names of those performing such duties, and the name of the person who authorized the termination of same. A copy of the entire Fire Watch Log, Notification of Fire Watch Responsibilities Form from each person assigned to fire watch, and documentation reflecting that the required fire protection system has been restored must be forwarded to Deer Park Fire Marshal's Office. Faxed to 281-478-7289, Emailed to firemarshal@deerparktx.org or delivered in person to Fire Station #3, 2211 East X Street, Deer Park, TX 77536.