

2211 East X Street  
Deer Park, Texas 77536  
(281) 478-7281  
(281) 478-7291  
[www.deerparktx.gov](http://www.deerparktx.gov)



H.W. Buddy Rice  
Fire Marshal

---

---

### COMMERICAL COOKING SUPPRESSION CHECKLIST

BUSINESS NAME: \_\_\_\_\_ DATE: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_ PERMIT NUMBER: \_\_\_\_\_  
INSTALLER: \_\_\_\_\_ LICENSE NUMBER: \_\_\_\_\_

- Approved set of plans and permit on site.
- Approved set of plans and permit on site
- UL 300 wet chemical system
- Provide proper coverage
- Observe activation of system through fuse link cutting
- Observe gas and all electric shut-off under hood, including lights
- Check nozzle operation by air blow-out test
- Gas shut off valve visible and accessible
- Make up air shut off and exhaust stayed on upon activation
- System tied into fire alarm and zoned correctly, if no building fire alarm a local bell is required
- Hood, duct and ventilation installed properly
- Manual pull in path of exit
- Class K extinguisher and sign within 30 feet of system
- System operated satisfactory
- System was reset and tagged properly

**SYSTEM PASSED TESTING**     YES     NO

Comments: \_\_\_\_\_  
\_\_\_\_\_

Fire Suppression System Installer: \_\_\_\_\_ Date: \_\_\_\_\_  
Fire Inspector: \_\_\_\_\_ Badge No. \_\_\_\_\_ Date: \_\_\_\_\_